



- NAPOMENA:
- Materijal cevne ploče mora biti ultrazvučno ispitan na dvoplasnost prema EN 10160.
  - Sve oštre ivice obraditi sa 1/45°.
  - Sve slobodne mere uraditi sa srednjim stepenom tačnosti prema SRPS ISO 2768-1.

3	Cevna ploča	1	P355GH	≠48xØ374	29	EN 10028-2
POZ.	NAZIV DELA	KOM.	MATERIJAL	DIMENZIJE	kg/kom	BR.CRT./STAND.
RAZMERA:		DATUM	IME	POTPIS	<div> <div>fm</div> <div>FEROMONT OPREMA A.D.</div> <div>PANČEVO</div> </div>	
KOPIJA:	KONSTRUIS. CRTAO	05.2022.	V.Popov	<i>V.Popov</i>		
	KONTROLISAO		M.Maričić	<i>M.Maričić</i>	ZAMENA ZA:	List / Listova
	ODOBRIO		D.Ninković	<i>D.Ninković</i>		
			NAZIV CRTEŽA:		BROJ CRTEŽA:	INV. BR.
			CEVNI SNOP		2580.430.00.03.3.0	3
			IZMENJIVAČA TOPLOTE EA-2601 A		VAŽI ZA:	
IZM.	DATUM	POTPIS	Cevna ploča		RN 015-2358 "NIS" a.d. Novi Sad Rafinerija nafte Pančevo	